



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun



TC-10477

ULR No.:TC104772300000000162F


Test Report ID: 317/UJS/DLWQTML/2023-24

Dated: 16/09/2023

TEST REPORT

Name and Address of Organization/ Customer	Shikshankur The Global School, Near ISBT, Haridwar Bypass Road, Dehradun, Uttarakhand		
Product Description	Drinking Water	Sample Description	One Water Sample collected from Shikshankur The Global School
Reference Sample Identification:	DLWQTML/UJS/2023-162		Date of Start of Analysis: 15/09/2023 Date of End of Analysis: 16/09/2023
Date and Time of Sample Received: 15/09/23 & 10:30 AM	Sample Collected by:		Customer:

S N	Parameters	Results	Acceptable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.42	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA: 2017: Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	240	500	2000	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Turbidity, NTU, Max	Less than 01	1	5	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	158	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	196	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Calcium as Ca, mg/l	33.6	75	200	IS 3025 (Part 21), 2009 RA:2019 (a) EDTA Titrimetric Method
7.	Chloride, mg/L, Max	42.14	250	1000	IS 3025 (Part 32): 1988, RA: 2019 Argentometric Method
8.	Magnesium as Mg, mg/l	27.21	30	100	APHA 23 rd -3500-Mg Method B:2017 (Calculation Method)
9.	Colour, Hazen, Max	Less than 01	5	15	IS 3025 (Part 4): 2021Platinum Cobalt (Visual Comparison)
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018


Vikash Khandelwal
Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

-End of Report -

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun



TC-10477

ULR No.:TC104772300000000162F


Test Report ID: 317/UJS/DLWQTML/2023-24

Dated: 16/09/2023

TEST REPORT

Name and Address of Organization/ Customer	Shikshankur The Global School, Near ISBT, Haridwar Bypass Road, Dehradun, Uttarakhand		
Product Description	Drinking Water	Sample Description	One Water Sample collected from Shikshankur The Global School
Reference Sample Identification:	DLWQTML/UJS/2023-162		Date of Start of Analysis: 15/09/2023
			Date of End of Analysis: 16/09/2023
Date and Time of Sample Received: 15/09/23 & 10:30 AM	Sample Collected by:		Customer:

S N	Parameters	Results	Acceptable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.42	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA: 2017: Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	240	500	2000	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Turbidity, NTU, Max	Less than 01	1	5	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	158	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	196	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Calcium as Ca, mg/l	33.6	75	200	IS 3025 (Part 21), 2009 RA:2019 (a) EDTA Titrimetric Method
7.	Chloride, mg/L, Max	42.14	250	1000	IS 3025 (Part 32): 1988, RA: 2019 Argentometric Method
8.	Magnesium as Mg, mg/l	27.21	30	100	APHA 23 rd -3500-Mg Method B:2017 (Calculation Method)
9.	Colour, Hazen, Max	Less than 01	5	15	IS 3025 (Part 4): 2021Platinum Cobalt (Visual Comparison)
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018


Vikash Khandelwal
Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

-End of Report -

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received