



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun



TC-13625

TEST REPORT

Name and Address of Organization/ Customer	Shikshankur The Global School, Near ISBT, Haridwar Bypass Road, Dehradun (Uttarakhand)		
Test Report ID	852/UJS/DLWQTML/2025-26	Reporting Date	26/06/2025
ULR No.	TC1362525000000000255F	Sample Location	Near ISBT, Haridwar Bypass Road, Dehradun
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-852		
Date of Start of Analysis:	25/06/2025		
Date of End of Analysis:	26/06/2025		
Date and Time of Sample Received:	25/06/25 & 10:42 AM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11) 2022	7.56	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16), 2023	134	500 Max	2000 Max
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.20	1 Max	5 Max
4.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 01	5 Max	15 Max
5.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
(B) General Parameters Concerning Substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	40	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	64	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	36.8	75 Max	200 Max
9.	Chloride, mg/L	IS 3025 (Part 32), 2019	16	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	12	30 Max	100 Max
(C) Microbiological Parameters					
SN	Parameters	Test Method	Results	Requirements as per IS 10500:2012	
11.	Total Coliform (absent/100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	
12.	E. coli (absent/100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	

Note:-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By

(Dr. Vikash Kandari)
Technical Manager, Lab

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 852/UJS/DLWQTML/2025-26

Dated: 26/06/25

It is certified that an inspection team headed by Dr. Vikash Khandelwal, Chief Chemist

(Name of Officers with designation) from Uttarakhand Jal Sansthan, PHED, Dehradun

inspected the Shikshanikur, The Global School, Near ISBT, Handwar Bypass Road, Dehradun

(Name & Address of the school) on 25/06/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 852/UJS/DLWQTML/2025-26 dated 26/06/25

of District Laboratory, UJS, Dehradun (PHED Lab) certified that

the Shikshanikur, The Global School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till as per Govt. norms.

Signature with Seal: [Signature]

Name

Designation

Name & Address of the Office / Department: UJS, Dehradun

To Shikshanikur, The Global School
Near ISBT, Handwar Bypass Road, Dehradun
(Name & Address of the Institution)

Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies